

# Zertifikat

# Certificate



Zertifikat Nr. *Certificate No.*  
R 50596677

Blatt *Sheet*  
0001

Ihr Zeichen *Client Reference*  
M.G.

Unser Zeichen *Our Reference*  
01-Dingjia-15046340

Ausstellungsdatum  
013 07.08.2023

*Date of Issue*  
(day/mo/yr)

Genehmigungsinhaber *License Holder*  
IDE Electric, SL  
C/Leonardo Da Vinci 2  
50800 Zuera  
España

Fertigungsstätte *Manufacturing Plant*  
040-0002165280

## Prüfzeichen *Test Mark*



Type Approved  
Safety  
Regular Production  
Surveillance

www.tuv.com  
ID 1111272840

Geprüft nach *Tested acc. to*  
EN 60898-1:2019

Zertifiziertes Produkt (Geräteidentifikation)  
*Certified Product (Product Identification)*

Lizenzentgelte - Einheit  
*License Fee - Unit*

Circuit Breaker (Circuit Breaker)

Type Designation : Z00AI (ide) 8  
Number of Poles : 1P/2P/3P/4P  
Rated Operational Voltage (Ue) : 240/415VAC (1P)  
415VAC (2/3/4P);  
Rated Frequency : 50/60Hz  
Rated Current (In) : 1/2/3/4/6/10/16/20  
25/32/40/50/63A  
Instantaneous Tripping Current : B-type or C-type  
Rated Short-circuit Capacity  
(Icn) : 6,0kA  
Rated Service Short-circuit  
Capacity (Ics) : 6,0kA  
Rated Insulation Voltage (Ui) : 500V  
Rated Impulse Withstand Voltage : 4,0kV  
Pollution Degree : 2  
Suitability for Isolation : Yes

8

Dem Zertifikat liegt unsere Prüf- und Zertifizierungsordnung zugrunde und es bestätigt die Konformität des Produktes mit den oben genannten Standards und Prüfgrundlagen. Zusätzliche Anforderungen in Ländern, in denen das Produkt in Verkehr gebracht werden soll, müssen zusätzlich betrachtet werden. Die Herstellung des zertifizierten Produktes wird überwacht.  
This certificate is based on our Testing and Certification Regulation and states the conformity of the product with the standards and testing requirements as indicated above. Any additional requirements in countries where the product is going to be marketed have to be considered additionally. The manufacturing of the certified product is subject to surveillance.

TÜV Rheinland LGA Products GmbH, Tillystraße 2, 90431 Nürnberg

http://www.tuv.com/safety E-mail: markcheck@tuv.com  
Fax: +49 221 806-3935

